



### OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on July 27, 2018.

Atlantium Technologies Ltd.  
11 HaMelacha Street  
99100 Har Tuv Industrial Park  
Israel  
800-596-2609  
972 2 992500

Facility: Har Tuv Industrial Park, Israel

#### Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
<b>Ultra-Violet Reactors</b> [1] [2] [G]			
R200 Hydro Optic Disinfection	6"	CLD 23	MLTPL
RS104 Hydro Optic Disinfection	4"	CLD 23	MLTPL
RZ104 Hydro Optic Disinfection	4"	CLD 23	MLTPL
RZ163 Hydro Optic Disinfection	6"	CLD 23	MLTPL
RZ300 Hydro Optic Disinfection	14"	CLD 23	MLTPL
RZB300 Hydro Optic Disinfection	14"	CLD 23	MLTPL

[1] Certified for use in municipal water treatment plants only.

[2] Certified for the following minimum flow rates (gallons per day):

- RZ104 and RS104 - 11,520
- RZ163 - 17,280
- R200 - 17,280
- RZB300 and RZ300 - 115,200

[G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.